

February 2021 Superintendent's Report

Wastewater Treatment Plant:

Operators performed routine repair and maintenance at the wastewater treatment plant during February 2021. We had a couple of alarm call outs in the middle of the night for influent pump power failure and continued problems with the Main St. lift station. The District is working with our Engineers and Plant Operations Committee to develop a plan to address both issues. The Superintendent completed and submitted the Annual State Self-Monitoring Report.

Recycled Water:

No transfers of recycled water were requested or made during January or February of 2021.

Biosolids Trailer and Transport:

Mendocino Coast Express safely hauled another load of Biosolids to Novato this past month.

Construction Project Update:

Construction is basically done, we are waiting on a project final from the Building Department, a walk through with the engineers and contractor, an electrical safety training from EATON, and a few punch list items. It appears at this time there will be enough money left in contingency to purchase a new-to-us, service truck.

Safety Meeting and Plant Safety Inspection:

The district is still following County, State, Federal, and CDC guidelines regarding COVID-19 safety precautions. The Safety Officer conducted the monthly safety inspection of the plant. The 30-minute monthly safety meeting was February 17, 2021. The topic was *Blood Borne Pathogens*.

Sanitary Sewer Overflow:

There were no MCCSD collection system sanitary sewer overflows to report during January 1, 2020 thru February 17, 2021.

Collection System:

MCCSD received a report of a possible small (Rabbit sized) sink hole on Evergreen St. near Pine St. Upon investigation a small (nickel sized) hole was located on the top of an old clay sewer main. The hole was allowing the surrounding sandy soil to slowly enter the main. The main was patched, and the hole was filled.